



MASTER FITTER ASSESSMENT – RESILIENT

OVERVIEW OF PRACTICAL ASSESSMENT

Training Centre assessment

Applicant will be required to correctly apply smoothing compound to an area of approximately 4m².

Applicant will be required to install 4mm plywood to the fitting bay (approx. 5m²).

Applicant will be required to install safety flooring to approximately half (left hand side) of the fitting bay area using cove former and capping seal which will require three internal corners and one external corner to be hot welded. The remaining half of the bay will be flat laid with smooth vinyl to include one small step and finished with a pvc nosing. The doorway to be finished with diminishing strip which along with the central join must be hot welded.

The area must be treated as a “live installation”. All relevant pre-installation checks must be observed.

Applicant will be required to bring with them all tools necessary to complete the installation, (to include all PPS and safety equipment)

All materials will be provided; however, applicant may supply own materials at the discretion of the assessor.